



Life Science Laboratories, Inc.

Harold VanHorn
Southern Cayuga Schools
2384 St. Rt. 34B
Aurora, NY 13026

Phone: (315) 364-7111

Laboratory Analysis Report

Prepared For

Southern Cayuga Schools

Client Project ID:

Southern Cayuga Schools

LSL Project ID: **1616182**

Receive Date/Time: 09/27/16 15:45

Life Science Laboratories, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose. By the Client's acceptance and/or use of this report, the Client agrees that LSL is hereby released from any and all liabilities, claims, damages or causes of action affecting or which may affect the Client as regards to the results contained in this report. The Client further agrees that the only remedy available to the Client in the event of proven non-conformity with the above warranty shall be for LSL to re-perform the analytical test(s) at no charge to the Client. The data contained in this report are for the exclusive use of the Client to whom it is addressed, and the release of these data to any other party, or the use of the name, trademark or service mark of Life Science Laboratories, Inc. especially for the use of advertising to the general public, is strictly prohibited without express prior written consent of Life Science Laboratories, Inc. This report may only be reproduced in its entirety. No partial duplication is allowed. The Chain of Custody and the Sample Receipt documents submitted with these samples are considered by LSL to be an appendix of this report and may contain specific information that pertains to the samples included in this report. The analytical result(s) in this report are only representative of the sample(s) submitted for analysis. LSL makes no claim of a sample's representativeness, or integrity, if sampling was not performed by LSL personnel.

LSL Central Lab
5854 Butternut Drive
East Syracuse, NY 13057
Tel. (315) 445-1900
Fax (315) 445-1104
NYS DOH ELAP #10248
PA DEP #68-2556

LSL North Lab
131 St. Lawrence Avenue
Waddington, NY 13694
Tel. (315) 388-4476
Fax (315) 388-4061
NYS DOH ELAP #10900

LSL Finger Lakes Lab
16 N. Main St., PO Box 424
Wayland, NY 14572
Tel. (585) 728-3320
Fax (585) 728-2711
NYS DOH ELAP #11667

LSL Southern Tier Office
Cuba, NY
Tel. (585) 209-4032

LSL MidLakes Office
Canandaigua, NY
Tel. (585) 728-3320

Reviewed by:

Date:

10/17/16

David J. Prichard, Director of Tech. Services

A copy of this report was sent to: Patrick Jansen
Southern Cayuga Schools

Date Printed:

Page 1 of 2

10/17/16

-- LABORATORY ANALYSIS REPORT --

Southern Cayuga Schools Aurora, NY

Sample ID: Lead Study LSL Sample ID: 1616182-001

Location:

Sampled: 09/27/16 5:00 Sampled By: HV

Sample Matrix: PW

Analytical Method	Prep Method	Prep	Analysis	Analyst
Analyte	Result Units	Date	Date & Time	Initials

(1) Lead Study

Number of Samples

80

MT

Please refer to the chain of custody form on the last page of this report for the detailed descriptions of where these samples were taken.

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-1

Lab ID: K1610107-001A
Collection Date: 09/27/16 5:00
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0014	mg/L	10/13/16 12:02

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-2**Lab ID:** K1610107-002A**Collection Date:** 09/27/16 5:01**Date Received:** 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0086	mg/L	10/13/16 12:13

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-3

Lab ID: K1610107-003A
Collection Date: 09/27/16 5:15
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0028	mg/L	10/13/16 12:17

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-4

Lab ID: K1610107-004A
Collection Date: 09/27/16 5:20
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0017	mg/L	10/13/16 12:21

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-5

Lab ID: K1610107-005A
Collection Date: 09/27/16 5:21
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0019	mg/L	10/13/16 12:24

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-6

Lab ID: K1610107-006A
Collection Date: 09/27/16 5:23
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0071	mg/L	10/13/16 12:28

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-7

Lab ID: K1610107-007A
Collection Date: 09/27/16 5:25
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	0.0026	EPA 200.8 mg/L	(E200.2) 10/13/16 12:32

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-8

Lab ID: K1610107-008A
Collection Date: 09/27/16 5:26
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	0.0032	EPA 200.8 mg/L	(E200.2) 10/13/16 12:43

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-9

Lab ID: K1610107-009A
Collection Date: 09/27/16 5:30
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	0.0043	EPA 200.8 mg/L	(E200.2) 10/13/16 12:47

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-10

Lab ID: K1610107-010A

Collection Date: 09/27/16 5:32

Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0055	mg/L	10/13/16 12:50

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-11

Lab ID: K1610107-011A
Collection Date: 09/27/16 5:34
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	< 0.0010	EPA 200.8 mg/L	(E200.2) 10/13/16 12:54

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-12

Lab ID: K1610107-012A
Collection Date: 09/27/16 5:34
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	0.020 *	EPA 200.8 mg/L	(E200.2) 10/13/16 12:58

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-13

Lab ID: K1610107-013A
Collection Date: 09/27/16 5:36
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	< 0.0010	mg/L	10/13/16 13:02

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-14

Lab ID: K1610107-014A
Collection Date: 09/27/16 5:37
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	0.0069	EPA 200.8 mg/L	(E200.2) 10/13/16 13:05

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-15

Lab ID: K1610107-015A
Collection Date: 09/27/16 5:38
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	0.0081	EPA 200.8 mg/L	(E200.2) 10/13/16 13:09

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-16

Lab ID: K1610107-016A
Collection Date: 09/27/16 5:50
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	< 0.0010	mg/L	10/13/16 13:13

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-17**Lab ID:** K1610107-017A**Collection Date:** 09/27/16 5:50**Date Received:** 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	< 0.0010	mg/L	10/13/16 13:17

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-18**Lab ID:** K1610107-018A**Collection Date:** 09/27/16 5:53**Date Received:** 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0021	mg/L	10/13/16 13:28

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-19

Lab ID: K1610107-019A
Collection Date: 09/27/16 5:53
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0019	mg/L	10/13/16 13:31

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-20

Lab ID: K1610107-020A
Collection Date: 09/27/16 5:54
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0023	mg/L	10/13/16 13:35

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-21

Lab ID: K1610107-021A
Collection Date: 09/27/16 5:54
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0034	mg/L	10/13/16 13:39

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-22

Lab ID: K1610107-022A
Collection Date: 09/27/16 5:57
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(EPA 200.2)
Lead	0.018 *	mg/L	10/13/16 13:50

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-23**Lab ID:** K1610107-023A**Collection Date:** 09/27/16 5:59**Date Received:** 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	< 0.0010	mg/L	10/13/16 13:54

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-24

Lab ID: K1610107-024A
Collection Date: 09/27/16 5:59
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	< 0.0010	EPA 200.8 mg/L	(E200.2) 10/13/16 13:58

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-25

Lab ID: K1610107-025A
Collection Date: 09/27/16 6:01
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0068	mg/L	10/13/16 14:01

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-26**Lab ID:** K1610107-026A**Collection Date:** 09/27/16 6:03**Date Received:** 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0075	mg/L	10/13/16 14:12

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-27

Lab ID: K1610107-027A
Collection Date: 09/27/16 6:02
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0057	mg/L	10/13/16 14:16

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-28

Lab ID: K1610107-028A
Collection Date: 09/27/16 6:04
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	0.0056	EPA 200.8 mg/L	(E200.2) 10/13/16 14:20

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-29

Lab ID: K1610107-029A
Collection Date: 09/27/16 6:04
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	0.010	EPA 200.8 mg/L	(E200.2) 10/13/16 14:24

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-30

Lab ID: K1610107-030A
Collection Date: 09/27/16 6:04
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.015	mg/L	10/13/16 14:27

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-31

Lab ID: K1610107-031A
Collection Date: 09/27/16 6:09
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0018	mg/L	10/13/16 14:31

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-32**Lab ID:** K1610107-032A**Collection Date:** 09/27/16 6:11**Date Received:** 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0058	mg/L	10/13/16 14:35

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-33**Lab ID:** K1610107-033A**Collection Date:** 09/27/16 6:11**Date Received:** 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0037	mg/L	10/13/16 14:39

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-34

Lab ID: K1610107-034A
Collection Date: 09/27/16 6:13
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	0.0018	EPA 200.8 mg/L	(E200.2) 10/13/16 14:42

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-35

Lab ID: K1610107-035A
Collection Date: 09/27/16 6:15
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	< 0.0010	mg/L	10/13/16 14:46

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-36

Lab ID: K1610107-036A
Collection Date: 09/27/16 6:15
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	< 0.0010	mg/L	10/13/16 15:09

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-37**Lab ID:** K1610107-037A**Collection Date:** 09/27/16 6:16**Date Received:** 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	< 0.0010	mg/L	10/13/16 15:12

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-38

Lab ID: K1610107-038A
Collection Date: 09/27/16 6:16
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0028	mg/L	10/13/16 15:16

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-39

Lab ID: K1610107-039A
Collection Date: 09/27/16 6:18
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0024	mg/L	10/13/16 15:20

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-40

Lab ID: K1610107-040A
Collection Date: 09/27/16 6:18
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	< 0.0010	mg/L	10/13/16 15:24

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-41

Lab ID: K1610107-041A
Collection Date: 09/27/16 0:00
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0018	mg/L	10/13/16 15:31

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-42

Lab ID: K1610107-042A
Collection Date: 09/27/16 0:00
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	0.0075	EPA 200.8 mg/L	(E200.2) 10/13/16 15:43

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-43

Lab ID: K1610107-043A
Collection Date: 09/27/16 6:25
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0068	mg/L	10/13/16 15:54

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-44

Lab ID: K1610107-044A
Collection Date: 09/27/16 6:27
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0016	mg/L	10/13/16 15:58

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-45

Lab ID: K1610107-045A
Collection Date: 09/27/16 6:28
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0040	mg/L	10/13/16 16:01

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-46

Lab ID: K1610107-046A
Collection Date: 09/27/16 6:30
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0035	mg/L	10/13/16 16:06

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-47

Lab ID: K1610107-047A
Collection Date: 09/27/16 6:30
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0062	mg/L	10/13/16 16:10

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-48

Lab ID: K1610107-048A
Collection Date: 09/27/16 6:30
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	0.0052	EPA 200.8 mg/L	(E200.2) 10/13/16 16:14

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-49

Lab ID: K1610107-049A
Collection Date: 09/27/16 6:45
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0036	mg/L	10/13/16 16:17

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-50

Lab ID: K1610107-050A
Collection Date: 09/27/16 6:45
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	0.0083	EPA 200.8 mg/L	(E200.2) 10/13/16 16:21

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-51

Lab ID: K1610107-051A
Collection Date: 09/27/16 6:45
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.011	mg/L	10/13/16 16:25

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-52

Lab ID: K1610107-052A
Collection Date: 09/27/16 6:46
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.010	mg/L	10/13/16 16:29

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-53

Lab ID: K1610107-053A
Collection Date: 09/27/16 6:50
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	< 0.0010	mg/L	10/13/16 16:40

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-54

Lab ID: K1610107-054A
Collection Date: 09/27/16 6:50
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	< 0.0010	mg/L	10/13/16 16:44

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-55

Lab ID: K1610107-055A
Collection Date: 09/27/16 6:52
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0073	mg/L	10/13/16 16:47

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-56

Lab ID: K1610107-056A
Collection Date: 09/27/16 6:54
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	< 0.0010	mg/L	10/13/16 16:51

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** SCS-57**Project:** 1616182-Southern Cayuga Schools**Location:** 0505868**Matrix:** PW**Lab ID:** K1610107-057A**Collection Date:** 09/27/16 6:54**Date Received:** 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0018	mg/L	10/13/16 16:55

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-58

Lab ID: K1610107-058A
Collection Date: 09/27/16 6:56
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	0.0012	EPA 200.8 mg/L	(E200.2) 10/13/16 16:59

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-59

Lab ID: K1610107-059A
Collection Date: 09/27/16 6:57
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0020	mg/L	10/13/16 17:03

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-60

Lab ID: K1610107-060A
Collection Date: 09/27/16 7:00
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0013	mg/L	10/13/16 17:06

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-61

Lab ID: K1610107-061A
Collection Date: 09/27/16 7:00
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0016	mg/L	10/13/16 17:10

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-62

Lab ID: K1610107-062A
Collection Date: 09/27/16 7:00
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	0.0012	EPA 200.8 mg/L	(E200.2) 10/13/16 17:29

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-63

Lab ID: K1610107-063A
Collection Date: 09/27/16 7:02
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0044	mg/L	10/13/16 17:33

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-64

Lab ID: K1610107-064A
Collection Date: 09/27/16 7:02
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	0.0014	EPA 200.8 mg/L	(E200.2) 10/13/16 17:36

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-65**Lab ID:** K1610107-065A**Collection Date:** 09/27/16 7:02**Date Received:** 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0011	mg/L	10/13/16 17:40

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-66

Lab ID: K1610107-066A
Collection Date: 09/27/16 7:04
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0087	mg/L	10/13/16 17:44

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-67**Lab ID:** K1610107-067A**Collection Date:** 09/27/16 7:06**Date Received:** 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.013	mg/L	10/13/16 17:48

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-68

Lab ID: K1610107-068A
Collection Date: 09/27/16 7:07
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0057	mg/L	10/13/16 17:52

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-69

Lab ID: K1610107-069A
Collection Date: 09/27/16 7:08
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	0.0015	EPA 200.8 mg/L	(E200.2) 10/13/16 17:55

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-70

Lab ID: K1610107-070A
Collection Date: 09/27/16 7:10
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0010	mg/L	10/13/16 18:07

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-71

Lab ID: K1610107-071A
Collection Date: 09/27/16 7:11
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	0.0059	EPA 200.8 mg/L	(E200.2) 10/13/16 18:10

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-72

Lab ID: K1610107-072A
Collection Date: 09/27/16 7:12
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0031	mg/L	10/13/16 18:14

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-73**Lab ID:** K1610107-073A**Collection Date:** 09/27/16 7:13**Date Received:** 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0085	mg/L	10/13/16 18:18

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-74

Lab ID: K1610107-074A
Collection Date: 09/27/16 7:15
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	< 0.0010	mg/L	10/13/16 18:22

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-75

Lab ID: K1610107-075A
Collection Date: 09/27/16 7:18
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0036	mg/L	10/13/16 18:25

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-76

Lab ID: K1610107-076A
Collection Date: 09/27/16 7:18
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(EPA 200.2)
Lead	0.017 *	mg/L	10/13/16 18:29

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-77

Lab ID: K1610107-077A
Collection Date: 09/27/16 7:20
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	< 0.0010	EPA 200.8 mg/L	(E200.2) 10/13/16 18:33

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-78

Lab ID: K1610107-078A
Collection Date: 09/27/16 7:20
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	< 0.0010	EPA 200.8 mg/L	(E200.2) 10/13/16 18:37

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-79

Lab ID: K1610107-079A
Collection Date: 09/27/16 7:24
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	0.013	EPA 200.8 mg/L	(E200.2) 10/13/16 18:41

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616182-Southern Cayuga Schools
Location: 0505868
Matrix: PW

Client Sample ID: SCS-80

Lab ID: K1610107-080A
Collection Date: 09/27/16 7:24
Date Received: 09/27/16 15:45

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0036	mg/L	10/13/16 18:52

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

Chain of Custody Record

Phone # (315) 445-1900 Telefax # (315) 445-1104

Client: Southern Cayuga Schools Phone # (315) 364-7111
Address: 2384 SRT 34B Fax #
Aurora, New York 13026

Contact Person: _____ LSL Project #: _____

Invoiced Government

200

Client's Site I.D.:

Authorization:

LSL Sample Number	Client's Sample Identifications	Sample Date	Sample Time	Type grab comp.	Matrix	Preserv. Added	Containers # size/type	Analyses	Free Cl (mg/L)	Pres. Check
1	Concession Stand	9-27-16	5:00 AM	X	PW	None	1 250 mL	Lead		<2
2	Concession Stand		5:01 AM	X			1			
3	District Off.		5:15 PM	X			1			
4	215		5:20	X			1			
5	213		5:21	X			1			
6	Corr. Drinking Fount		5:23	X			1			
7	Weight Room Sink		5:25	X			1			
8	Weight Room Drink. Fnd.		5:26	X			1			
9	Boys Lockerroom		5:30	X			1			
10	Maintenance Shop		5:32	X			1			
11	Drinking Fountain		5:34	X			1			
12	Drinking Fount. Filler		5:34	X			1			
13	Kitchen Kettle Fill.		5:36	X			1			
14	Kitchen Food Prep		5:37	X			1			

Client's Project I.D.: 0505868

Notes and Hazard Identifications:

* Samples Preserved
Upon Receipt at Lab

Custody Transfers

Sampled and Relinquished By:	Signature:	Date	Time
Print Name: <u>Harold G. Vanthorn</u>	<u>[Signature]</u>		
Relinquished By:	Received By: <u>[Signature]</u>		
Relinquished By: <u>[Signature]</u>	Received for Lab By: <u>R. Duke</u>	9/27/16	15:45
Shipment Method: <u>21°C</u>			

Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057

Chain of Custody Record

1616182

Invoiced Government

Telephone # (315) 445-1104

LSL Project #:

Phone # (315) 344-7111

Client: Southern Cayuga Schools

Address: 2384 State St

Fax #

Aurora, New York 13026

200

Client's Site I.D.:

Authorization:

Client's Project I.D.: 0505868

LSL Sample Number	Client's Sample Identifications	Sample Date	Sample Time	Type	Matrix	Preserv.		Containers	Analyses	Free Cl (mg/L)	Pres. Check
						Added	#				
15	155cs-015	9-23-16	5:38	X	PW	None *	1	250 mL	Lead		<2
16	Cafeteria Drinking Fw	9-23-16	5:40	X			1				
17	Cafeteria Bottle Filler	9-23-16	5:40	X			1				
18	Conn. N wall (DF)	9-23-16	5:50	X		*	1				<2
19	Conn. N wall (DF)	9-23-16	5:50	X			1				
20	Girls Bath #1	9-23-16	5:53	X			1				
21	Girls Bath #2	9-23-16	5:53	X			1				
22	Boys Bath #1	9-23-16	5:54	X			1				
23	Boys Bath #2	9-23-16	5:54	X			1				
24	H.S. Nurse Sink	9-23-16	5:57	X			1				
25	Drinking fnd. new stage	9-23-16	5:59	X			1				
26	"	9-23-16	5:59	X			1				
27	H.S. Faculty Room	9-23-16	6:01	X			1				
28	Boys Bath #	9-23-16	6:07	X			1				

Notes and Hazard Identifications:

Custody Transfers

Sampled and Relinquished By:		Signature:		Date	Time
Print Name: Harold G. Vanden		<i>Harold G. Vanden</i>			
Relinquished By:		Received By:			
<i>Harold G. Vanden</i>		<i>Justin</i>			
Relinquished By:		Received By:			
<i>Justin</i>		<i>R.D. Duke</i>		9/27/16	15:45
Relinquished By:		Received for Lab By:			
Shipment Method:		Samples Received Intact:		Y	N
					210C

* Samples Preserved
Upon Receipt at Lab

Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057

Chain of Custody Record

1616182

Phone # (315) 445-1900

Telefax # (315) 445-1104

Client: Southern Cayuga Schools

Phone # 615 364-7111

Address: 2384 Rt 34B

Fax #

Aurora, New York 13026

Contact Person:

LSL Project #:

Invoiced Government

200

Client's Site I.D.:






Authorization:

Client's Project I.D.: 0505868

LSL Sample Number	Client's Sample Identifications	Sample Date	Sample Time	Type	Matrix	Preserv. Added	Containers		Analyses	Free Cl (mg/L)	Pres. Check
							#	size/type			
2935-027	Boys Bath #2	9-27-11	6:02	X	PW	None	1	250 mL	Lead		2Q
30	Girls Bath #1		6:08	X			1				
31	Girls Bath #2		6:04	X			1				
32	Girls Bath #3		6:04	X			1				
33	315		6:09	X			1				
34	311 Sink #1		6:11	X			1				
35	311 Sink #2		6:11	X			1				
36	Music		6:13	X			1				
37	Corr. Drinking Fount.		6:15	X			1				
38	Corr. Drinking Fount.		6:15	X			1				
39	Girls Lock. #1		6:16	X			1				
40	Girls Lock. #2		6:16	X			1				
41	Corr. near 406		6:18	X			1				
42	Corr. near 405		6:18	X			1				

Notes and Hazard Identifications:

Custody Transfers

Sampled and Relinquished By:		Signature:		Date	Time
Print Name: Harold G. Vanston					
Relinquished By:		Received By:			
					
Relinquished By:		Received for Lab By:			
				9/27/10	15:45
Shipment Method:		Samples Received Intact: Y N			
		21°C			

* Samples Preserved
Upon Receipt at Lab

Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057

Chain of Custody Record

1616182

Invoiced Government

Phone # (315) 445-1900

Contact Person:

LSL Project #:

Telefax # (315) 445-1104

Client: Southern Cayuga Schools Phone # (315) 364-7111

Address: 2384 Rt 34B Fax #

Aurora, New York 13026

Client's Site I.D.:

Authorization:

Containers

Client's Project I.D.: 0505868

LSL Sample Number	Client's Sample Identifications	Sample Date	Sample Time	Type	Matrix	Preserv. Added	#	size/type	Analyses	Free Cl (mg/L)	Pres. Check
43	345-041	Dark, fund. near 345	9-27-14	X	PW	None	1	250 mL	Lead		22
43	a, 042	" " " #329		X			1				
44	043	" " " #503	6:26	X			1				
45	044	" " " #512	6:27	X			1				
46	045	Faculty Rom. #572	6:28	X			1				
47	046	EH: Boys Bath #1	6:30	X			1				
48	047	" " " #42	6:30	X			1				
49	048	" " " #3	6:30	X			1				
50	049	Girls Bath #1	6:35	X			1				
51	050	Girls Bath #2	6:35	X			1				
52	051	Girls Bath #3	6:45	X			1				
53	052	EH Nurse	6:46	X			1				
54	053	Drink fountain #520	6:50	X			1				
55	054	Drink fund. near 520	6:50	X			1				

Notes and Hazard identifications:

Custody Transfers

Date

Time

Sampled and Relinquished By:

Print Name: Harold G. Vanthorn

Signature:

Received By:

Received By:

* Samples Preserved

Upon Receipt at Lab

Relinquished By:

Relinquished By:

Received for Lab By:

Received By:

Received By:

Relinquished By:

Relinquished By:

Received for Lab By:

Received By:

Received By:

Shipment Method:

Samples Received Intact: Y N

210C

9/27/14 1545

Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057




Chain of Custody Record

1616182

Client:	Southern Cayuga Schools	Telefax # (315) 445-1104	Contact Person:	LSL Project #:	Invoiced Government
Address:	2384 State St	Phone # (315) 344-7111			200
	Aurora, New York 13026	Fax #		Client's Site I.D.:	

LSL Sample Number	Client's Sample Identifications	Sample Date	Sample Time	Type	Authorization:			Matrix	Preserv. Added	Containers		Analyses	Free Cl (mg/L)	Pres. Check
					grab	comp.	size/type			#	250 ml			
5685-055	E 508	9-27-14	6:52	X				PW	None*	1		Lead		22
57 056	E 511 #1		6:54	X						1				
58 057	E 511 #2		6:54	X						1				
59 058	E 515		6:56	X						1				
60 059	E 517		6:57	X						1				
61 060	K-1 Boys Bath #1		7:00	X						1				
62 061	" #2		7:00	X						1				
63 062	" #3		7:00	X						1				
64 063	K-1 Girls Bath #1		7:02	X						1				
65 064	" #2		7:02	X						1				
66 065	" #3		7:02	X						1				
67 066	E 519		7:04	X						1				
68 067	E 520		7:06	X						1				
69 068	E 522		7:07	X						1				

Notes and Hazard Identifications:	Custody Transfers			Date	Time
	Sampled and Relinquished By:	Signature:			
	Print Name: Harold G. Vanthorn				
	Received By:				
* Samples Preserved Upon Receipt at Lab	Relinquished By:				
	Relinquished By:	Received for Lab By:			
Shipment Method:			Samples Received Intact: Y N		
			210C		



5854 Butternut Drive

East Syracuse, NY 13057

Phone # (315) 445-1900

Telefax # (315) 445-1104

Client: Southern Cayuga Schools Phone # (315) 364-7111

Phone # (315) 364-7111

Address: 2384 St Kl 34 B

Fax #

Aurora, New York 13026

Chain of Custody Record

Contact Person:	LSL Project #:
-----------------	----------------

Telefax # (315) 445-1104

1616182

Client's Site I.D.:	Invoiced_Government
	200

Authorization:

LSL Sample Number	Client's Sample Identifications	Sample Date	Sample Time	Type		Matrix	Preserv. Added	Containers		Analyses	Free Cl (mg/L)	Pres. Check
				grab	comp.			#	size/type			
700-069	E 521	9-17-11	7:08	X		PW	None *	1	250 mL	Lead		22
71 070	E 523		7:10	X				1				
72 071	E 524		7:11	X				1				
73 072	E 525		7:12	X				1				
74 073	E 526		7:13	X				1				
75 074	EH Drink Font. Lockdown		7:15	X				1				
76 075	Girls Lockdown EH #1		7:18	X				1				
77 076	" #2		7:18	X				1				
78 077	EH Cafe Drink Font.		7:20	X				1				
79 078	EH " "		7:20	X				1				
80 079	EH Kitchen		7:24	X				1				
81 080	EH Kitchen		7:24	X				1				
				X				1				
				X				1				

Notes and Hazard identifications:

Custody Transfers

Sampled and Relinquished By:

Print Name: Harold G. Venter

Signature:

*** Samples Preserved**

Upon Receipt at Lab

Relinquished By:

Received By:

Relinquished By: W. J. C.

Received for Lab Rv.

5

Shipment Method:

Samples Received Intact. **V** **N**

210C